

CENTRAL POWER RESEARCH INSTITUTE
(Member of STL)



TEST REPORT

Test Report Number	SC16577	Dated: 24 th October, 2016
Name & Address of the Customer	M/s. Pragati Electrocom (P) Ltd., Plot No. 184, Sector 3, IMT Manesar, Gurgaon, Haryana – 122050, India.	
Name & Address of the Manufacturer	M/s. Pragati Electrocom (P) Ltd., Plot No. 184, Sector 3, IMT Manesar, Gurgaon, Haryana – 122050, India.	
Particulars of sample tested	Earth Electrode	
Condition of the sample on Receipt	New	
Type	Pipe-in-pipe	
Description of test sample	GI Pipe-in-pipe Earth Electrode	
Serial Number(s)	---	
Number of samples tested	One	
Date (s) of test (s)	4 th October, 2016	
CPRI sample code no(s).	SC16S0962	
Particulars of tests conducted	Short-time withstand current and peak withstand current	
Test in accordance with	Customer's instruction	
Standard / specification	Not applicable	
Sampling plan	20 kA rms for 1.0 s & 40 kA peak	
Customer's requirement	---	
Deviations if any	---	
Name of the witnessing persons		
Customer's representative	Mr. K. K. Rajpal	
Other than customer's representative	None	
Test subcontracted with address of the laboratory	None	
Documents constituting this report (In words)		
Number of sheets	Four	
Number of oscillograms	One	
Number of graphs	Nil	
Number of photos	Two	
Number of test circuit diagrams	One	
Number of drawings	One	


(Sakthivel. P)
Test Engineer




(R. A. Deshpande)
Additional Director